

Town Manager's Report
FEBRUARY 2016
Prepared by David Haller

Streets:

- Staff repaired a few streetlights.
- Staff installed 'slow children at play' signs
- Staff cleaned and salted sidewalks
- Staff hauled snow out of parking spaces

Water:

- Rainbow Lake is now at the spillway level.
- The roughing filters are being backwashed one time a day and the DE filters are being done once per week.
- Our wells are now on average 7.0' below their May 2011 levels.
- Water production and consumption. We produced and purchased an average of 313,731 GPD. We consumed an average of 281,077 GPD.

The difference is "Backwash Water" ... (10.4%). We purchased 363,200 gallons of water from MSM this month.

- 42.7% of this water came from wells.
- 4.0% of this water came from Mt. St. Mary's.
- 53.3% of this water came from Rainbow Lake.

Wastewater:

- The overland flow treatment system is shut down.
- We received about 5.2" of precipitation this month (the average is 3.0").
 - We have a precipitation **SURPLUS** of 13.0" over the last six months. The average precipitation for the period from Sept 1 thru February 29 is 21,5". We have received 34.5" for that period.
- Wastewater Treatment:
 - We treated an average of 990,000 GPD (consumed 281,077 GPD) which means that 71.6% of the wastewater treated this month was "wild water".
 - We had no spills of untreated sewerage in the month of September.
 - We exceeded the plant's design capacity on fourteen days in the month of February.

02/01	961,000 GPD	02/02	929,000 GPD	02/03	3,840,000 GPD
02/04	2,003,000 GPD	02/05	1,051,000 GPD	02/06	763,000 GPD
02/16	2,040,000 GPD	02/17	1,137,000 GPD	02/18	845,000 GPD
02/21	905,000 GPD	02/23	954,000 GPD	02/24	2,663,000 GPD
02/25	1,321,000 GPD	02/26	777,000 GPD		

Trash: Trash pickup will remain Mondays for the remainder of the month of March.

Parks:

- Staff performed monthly checks in all parks.

I Recently Attended the Following Meetings:

- 02/23 Attended staff meeting
- 02/29 Met with Mayor and Town Attorney